

DATE: April 29, 2024


TO: Plan Holders

SUBJECT: PRE-BID SUBMITTED QUESTIONS AND RESPONSES

HL-0004 - 17th Street Extension

City of Hickory

(Bids to be opened and read Thursday, May 9, 2024 at 2:00 p.m.)



The following are pre-bid questions that were submitted by various bidders (additional questions from 04/22/24 to 04/26/24). Responses follow and are denoted in red.

- 1. What size are the electrical junction boxes? Is there a different size for the 4” verses the 2” or with the conduits both come up in the same box, or will the 4” conduit box be side by side of the 2”?**

Two different size junction boxes will be used on this project and they will be paid as two separate line items. A special provision has been added to the UC special provisions noting that the size and location of the electrical junction boxes will be as directed by the Engineer. With that said, the intent of the City is for the 4” conduit to come up into 24”x36” junction boxes (spaced at approximately 500’ spacing) and the 2” conduit to come up into 12”x18” junction boxes at each light pole (spaced at approximately 50’ spacing).