



**City of Hickory
Engineering Department**

76 N Center St NE
Hickory, NC 28601
Phone: (828) 323-7558
sabernethy@hickorync.gov

ADDENDUM NO. 1

Patrick Beaver Stage
City of Hickory Bid Number 25-003
September 13th, 2024

The information listed below revises, supersedes and clarifies the bid documents issued for this project. These items should be incorporated in their entirety into your final bids. Any questions regarding this addendum should be directed to Sam Abernethy PE, Civil Engineer, City of Hickory at (828) 323-7558.

1. **(Included) Fencing Detail** – Typically, we have used Fister Fence, but we are open to an approved equal.
2. **Patrick Beaver Stage Drawings**
 - Conduit** Two (2) 1-inch schedule 40 PVC conduits will now be required.
 - Trees** Existing trees to be removed by city forces. Contractors will be responsible for grubbing any stumps encountered while doing site work.
 - Gutters** See modified alignment for gutter drains on the drawing including two (2) 1’x1’ plastic catch basins at the gutter down spouts.

General responses to question from the Pre-Bid meeting:

Gutters

- The building manufacturer, Poligon, will not provide the gutter materials that are to be installed.
- Two (2) downspouts will discharge to the gutter drains shown on the most recent set of plans.
- Poligon will provide an element to the structure to act as a fascia board where gutters may be installed. Top of gutters are expected to sit level despite angle of fascia board provided.

Solid Waste

- Solid waste shall not be disposed of in the existing dumpster on site.
- Waste shall be removed from the site by methods determined by the contractor. A construction dumpster may be placed in the westernmost employee parking area as specified by the library director.

Amphitheater

- The shelter manufacturer has a 12-week construction period once ordered. This will start after the contractor is selected.
- Any delays to the project caused by the shelter manufacturer will not count toward liquidated damages.

This addendum is now listed on Public Purchase section of our webpage at [Purchasing | City of Hickory \(hickorync.gov\)](https://www.hickorync.gov/purchasing)

Please acknowledge receipt of this addendum along with its date on the bid form. Bids will not be accepted without acknowledgement.